

Message

From: Baron, Adam [/O=EXCHANGELABS/OU=EXCHANGE ADMINISTRATIVE GROUP (FYDIBOHF23SPDLT)/CN=RECIPIENTS/CN=563EF058707D4930868C6CF1E0828A43-BARON, ADAM]
Sent: 9/3/2019 5:17:23 PM
To: Thurmon, Clarke [/o=ExchangeLabs/ou=Exchange Administrative Group (FYDIBOHF23SPDLT)/cn=Recipients/cn=4ee51ecf20b146d18fb2874c6b0d1b31-Thurmon, Clark]
Subject: FW: EPA R10 review of monitoring data related to Warm Springs BWN



Adam Baron

Drinking Water Enforcement Officer
Field, Data, & Drinking Water Enforcement Section
Enforcement and Compliance Assurance Division
U.S. Environmental Protection Agency, Region 10
1200 Sixth Avenue, Suite 155
Seattle, Washington 98101
Office (206) 553-6361
baron.adam@epa.gov

From: Ellen H. Grover <ehg@karnopp.com>
Sent: Wednesday, August 14, 2019 7:44 PM
To: Alyssa Macy <alyssa.macy@wstribes.org>
Cc: Chico Holliday <chico.holliday@wstribes.org>; Baron, Adam <Baron.Adam@epa.gov>; Affeldt, Chris <Affeldt.Christopher@epa.gov>; Contreras, Peter <Contreras.Peter@epa.gov>; Duvil, Ricardi <duvil.ricardi@epa.gov>; Thurmon, Clarke <Thurmon.Clarke@epa.gov>; Travis Wells <travis.wells@wstribes.org>
Subject: Re: EPA R10 review of monitoring data related to Warm Springs BWN

Congratulations. Good work WS crew!

Sent from Ellen's iPhone 6

On Aug 14, 2019, at 4:24 PM, Alyssa Macy <alyssa.macy@wstribes.org> wrote:

Thank you! I will draft a public notice indicating this has occurred and distribute. It will be in about an hour and a half, I am just getting to a meeting.

On Wed, Aug 14, 2019, 4:19 PM Chico Holliday <chico.holliday@wstribes.org> wrote:

Thank you!

On Wed, Aug 14, 2019 at 4:10 PM Baron, Adam <Baron.Adam@epa.gov> wrote:

<image001.gif>

Travis/ Chico/ Alyssa -

I've recently reviewed the Warm Springs Water Treatment Plant's (WSWTP) bacteriological results for total coliform and E. coli, along with chlorine residual levels sampled on August 12 and 13, 2019. Based on information provided by the Warm Springs Tribe today after the line/ PRV repair was completed, sampling results indicate that both total coliform and E. coli were absent and free chlorine residual levels have returned to baseline levels. As a result, the EPA Region 10 concurs with Warm Springs assessment that the BWN for WSWTP can be lifted.

Thanks.

<image002.png>

Adam Baron

Drinking Water Enforcement Officer

Field, Data, & Drinking Water Enforcement Section

Enforcement and Compliance Assurance Division

U.S. Environmental Protection Agency, Region 10

1200 Sixth Avenue, Suite 155

Seattle, Washington 98101

Office (206) 553-6361

baron.adam@epa.gov

--

Chico Holliday
Water/wastewater Supervisor
541-460-2707 (c)
541-615-0962 (w)
chico.holliday@wstribes.org

Electronic Privacy Statement. This e-mail message, including any attachments, is intended only for the use of the individual or entity to which it is addressed and may contain information that is privileged and/or confidential. If you are not the intended recipient or the employee or agent responsible for delivering the communication to the intended recipient, please notify us immediately by replying to this message and then delete this message from your system. You are

hereby notified that any use, dissemination, distribution and/or reproduction of this message and/or any attachments by unintended recipients is unauthorized and may be unlawful.

CONFIDENTIALITY NOTICE: The information contained in this e-mail is intended only for the use of the designated recipients named above. This email, and any documents, files or previous e-mails attached to it, may be a confidential attorney-client communication or otherwise privileged and confidential. If you are not the intended recipient, you are hereby notified that you have received this transmittal in error, and that any review, dissemination, distribution or copying of the transmittal is STRICTLY PROHIBITED. If you have received this e-mail in error, please notify us immediately by telephone (call us collect at 541.382.3011). Thank you.